

Manufacturing Plant : Clow Canada, Saint John, New Brunswick

Production Description : D67M - Premier Fire Hydrant

Product Design / Testing : AWWA C502, Dry-Barrel Fire Hydrants (250psi rating)
AWWA C550, Protective Interior Coatings for Valves and Hydrants
(ULC) Underwriters Laboratories of Canada
(FM) Factory Mutual
UL (Underwriters Laboratories) in accordance with **ANSI/NSF 61 and ANSI/NSF 372**
(LEAD CONTENT VERIFICATION OF PRODUCTS INCONTACT WITH POTABLE WATER)

Size : 5" **Type :** Dry Barrel

Quantity : **Cat. No. :** D67M

Material Specifications and Test Details :

Clow Canada models are manufactured to the following material specifications

<u>Materials</u>	<u>ASTM Standard</u>
Cast Iron	A-126-B
Ductile Iron	A-536 65-45-12
Bronze	B-584 87850 Alloy
Bronze	B-584 867 Alloy (Tripod)
Steel Bar Stock (Stem)	A-576
Stainless Steel (Upper Stem)	416 MX


Hydrostatic Test: **Shell: 500 p.s.i.** **SEAT: 500 p.s.i.**

We hereby certify that the above products were inspected and tested in accordance with relevant specifications and found acceptable.


Quality Assurance


Date


Plant Manager


Date