

**Manufacturing Plant :** Clow Canada, Saint John, New Brunswick

**Production Description :** D67M - Premier Fire Hydrant

**Product Design / Testing :** AWWA C502, Dry-Barrel Fire Hydrants (250psi rating)  
AWWA C550, Protective Interior Coatings for Valves and Hydrants  
(ULC) Underwriters Laboratories of Canada  
(FM) Factory Mutual  
UL (Underwriters Laboratories) in accordance with ANSI/NSF 61 and ANSI/NSF 372  
(LEAD CONTENT VERIFICATION OF PRODUCTS INCONTACT WITH POTABLE WATER)

**Size :** 5"                      **Type :** Dry Barrel

**Quantity :**                      **Cat. No. :** D67M

---

**Material Specifications and Test Details :**

Clow Canada models are manufactured to the following material specifications

<u>Materials</u>	<u>ASTM Standard</u>
Cast Iron	A-126-B
Ductile Iron	A-536 65-45-12
Bronze	B-584 87850 Alloy
Bronze	B-584 867 Alloy (Tripod)
Steel Bar Stock (Stem)	A-576
Stainless Steel (Upper Stem)	416 MX

**Hydrostatic Test:**                      **Shell: 500 p.s.i.**                      **SEAT: 500 p.s.i.**

---

We hereby certify that the above products were inspected and tested in accordance with relevant specifications and found acceptable.

  
Quality Assurance

  
Date

  
Plant Manager

  
Date