CLOW

CERTIFICATE OF COMPLIANCE

Canada

Manufacturing Plant:

Clow Canada, Saint John, New Brunswick

Production Description:

D67M - Premier Fire Hydrant

Product Design / Testing: AWWA C502, Dry-Barrel Fire Hydrants (250psi rating)

AWWA C550, Protective Interior Coatings for Valves and Hydrants

(ULC) Underwriters Laboratories of Canada

(FM) Factory Mutual

UL (Underwriters Laboratories) in accordance with ANSI/NSF 61 and ANSI/NSF 372 (LEAD CONTENT VERIFICATION OF PRODUCTS INCONTACT WITH POTABLE WATER)

Size: 5"

Type: Dry Barrel

Quantity:

Cat. No.: D67M

Material Specifications and Test Details:

Clow Canada models are manufactured to the following material specifications

Materials

ASTM Standard

Cast Iron

A-126-B

Ductile Iron

A-536 65-45-12

Bronze

B-584 87850 Alloy

Bronze

B-584 867 Alloy (Tripod)

Steel Bar Stock (Stem)

A-576

Stainless Steel (Upper Stem)

416 MX

Hydrostatic Test:

Shell: 500 p.s.i.

SEAT: 500 p.s.i.

We hereby certify that the above products were inspected and tested in accordance with relevant specifications and found acceptable.

Quality Assurance

Plant Manager

Oct 18 2023

Oct 18 2023